

AUGUSTA TOWNSHIP



RFP 2024-06

REQUEST FOR PROPOSAL FOR OUTDOOR ELECTRONIC SIGN

ADDENDUM No. 1

The following addendum shall be attached to and form part of Contract No. 2024-06

1. Q. Would it be possible to have an extension (min 1 week) as we need to get electrical pricing finalized, and in relation to the complexity of the build of the option # 2.

A. The **New** closing date for Tender 2024-06 is May 7, 2024 at 2pm.

2. Q. There is electrical to the existing board structure, what is the voltage and amperage being sent to the existing board structure?

A. The voltage is 120V and the amperage is 15A.